

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Amendment No. 3
to
AS/NZS 3823.1.1:1998
Performance of electrical appliances—Airconditioners and heat pumps
Part 1.1: Non-ducted air conditioners and heat pumps—Testing and rating of performance

REVISED TEXT

The 1998 edition of AS/NZS 3823.1.1 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to the Preface and Appendix ZZ.

Published on 24 February 2006.

Approved for publication in New Zealand on behalf of the Standards Council of New Zealand on 21 December 2005.

Preface

Add the following references after AS/NZS 1677.1:

AS/NZS

3823 Performance of electrical appliances—Airconditioners and heat pumps

3823.1.3 Part 1.3: Water-source heat pumps—Water-to-air and brine-to-air heat pumps—Testing and rating of performance

62301 Household electrical appliances—Measurement of standby power

Clause 1.1

Delete Clause 1.1 as amended by Amendment No. 2 2002 and *replace* with the following:

This Standard specifies the conditions on which the capacity and energy consumption of factory-made residential, commercial and industrial electrically driven, mechanical-compression, single-package and split-system non-ducted airconditioners employing air-cooled condensers and non-ducted air-to-air heat pumps are based. The Standard also specifies the test methods to be applied for determining the capacity and efficiency ratings. This Standard covers equipment utilizing one or more refrigeration systems with one outdoor unit and one or more indoor units controlled by a single thermostat/controller. This Standard covers equipment utilizing single, multiple and variable capacity components.

NOTE: Air conditioners with water cooled condensers have been excluded from this part and are now covered under the requirements of AS/NZS 3823.1.3.

Clause 1.3

Add the following sentence:

(e) individual evaporator/condenser assemblies for separate use.

AMDT
No. 3
FEB
2006

AMDT
No. 3
FEB
2006

AMDT
No. 3
FEB
2006

AMDT
No. 3
FEB
2006

Clause 1.7

Delete Clause 1.7 and *replace* with the following:

This Standard does not cover the determination of seasonal efficiencies which may be required in some countries.

AMDT
No. 3
FEB
2006

Table 5

Delete 'High' and *insert* 'H1', *delete* 'low' and *insert* 'H2', *delete* 'extra low' and *insert* 'H3'.

AMDT
No. 3
FEB
2006

Clause 6.5 and 6.6

Add new Clauses

6.5 Standby power and crank case heaters

Measurements of standby power and crank case heater power shall be undertaken in accordance with the procedures and instruments specified in AS/NZS 62301 and shall be determined for the following modes (as applicable) on the airconditioner:

- (a) Off mode (where applicable).
- (b) Passive standby mode (where applicable).
- (c) Delay start mode (where applicable).
- (d) Average crank case heater power for various outdoor conditions.

Power in each applicable mode shall be reported in Watts to the nearest 0.1 W or better.

6.5.1 Off mode

Where the air conditioner is not operational and where the air conditioner has no remote control or automatic program functions or these are inoperative. This mode is the lowest power consumption mode that cannot be switched off (influenced) by the user and that persists for an indefinite time when an appliance is connected to the mains electricity supply and used in accordance with the manufacturer's instructions. Measurements of crank case heaters (where present) shall be reported separately to this mode (see below) where possible.

NOTE: Products may use some power in off mode to supply electronic controls.

6.5.2 Passive standby mode

If present, where the airconditioner is not operational but where it has a remote control and/or is monitoring for a signal from a remote source or where there is a timer with some programming capability (e.g., timed or delay start). This mode includes those with remote communications capability where this facility is active. Where there are several possible power levels in this mode, the power for each shall be recorded with a description of its function. Measurements of crank case heaters (where present) shall be reported separately to this mode (see below) where possible.

6.5.3 Delay start mode

If present, is where the model has a separate user option that is used to delay the commencement operation (only where this function is not included as part of passive standby mode).

6.5.4 Crank case heaters

Where an airconditioner has a crankcase heater (a small resistive heater attached to the compressor sump or crankcase (the sump is where oil and some refrigerant collects when the unit is not operating)), the following readings shall be undertaken:

- (a) Average heater power (Watts) with the section containing the compressor under a dry bulb ambient temperature of 20 deg C +/-2K.
- (b) Average heater power (Watts) with the section containing the compressor under a dry bulb ambient temperature of 7 deg C +/-2K.

Readings shall be measured over a period of not less than 3 hours. Where the heater exhibits any regular cyclic behaviour, a whole number of cycles shall be used to determine the average power.

Where the ambient temperature does not influence the power consumption of the crankcase heater the measurement may be conducted at any ambient temperature. Manufacturers may declare the values for (a) and (b) above based on measurements and knowledge of the control of the crankcase heater. For verification purposes a combination of analysis of the control system and measurements may be used to assess compliance, but a measurement at the specified conditions shall have precedence over any other method.

6.6 Testing airconditioners with variable output compressors

Some types of variable output capacity air conditioners may require the setting of non-user accessible controls to lock the output capacity at the rated capacity (or part load capacity) specified by the manufacturer. Where special tools or software are required to perform this function, the manufacturer shall provide the tools or software to the laboratory.

For 50% part load performance testing, in the absence of manufacturer's information a compressor speed of 50% of the rated compressor speed may be used.

Table 12

Delete the variation to Table 12 and replace with the following:

Delete the words 'from rating conditions' from the heading in the third column and *delete* all '±' symbols from 3rd column. *Delete* the figures '0.5 °C' (twice) from the 3rd column and *insert* '0.6 °C' (twice).
